

<https://www.osha.gov/laws-regs/regulations/standardnumber/1910/1910.105>

Extracted by GlobalMSDS Ltd

12 March 2019

The piped systems for the in-plant transfer and distribution of nitrous oxide shall be designed, installed, maintained, and operated in accordance with Compressed Gas Association Pamphlet G-8.1-1964, which is incorporated by reference as specified in Sec. 1910.6.

[61 FR 9237, March 7, 1996]